## Heimani田曼 深圳市海曼科技股份有限公司 Shenzhen Heiman Technology Co.,Ltd.

Doc No.: 20181215001

### **DECLARATION OF PERFORMANCE**

\_\_\_\_\_

Ver.:1.2

Effective Date:2022.09.16

- Unique identification code of the product-type: HS1SA, HS1SA-M, HS1SA-E, HS1SA-Z, HS1SA(WHITE), HS1SA-M(WHITE), HS1SA-E(WHITE), HS1SA-Z(WHITE) HS3SA, HS3SA-E, HS3SA-Z
- 2. Intended use or uses of the construction product: Fire Safety
- Name and contact address of the manufacturer: Shenzhen Heiman Technology Co., Ltd. 101, No.4 Dafu Industrial Park, Kukeng Community, Guanlan Street, Longhua District Shenzhen 518110 China
- Where applicable, name and contact address of the authorized representative: THEMIS AR Unterstützung UG Address: Beedstrasse 54, In Dusseldorf, (40468), Deutschland
- System or systems of assessment and verification of constancy of performance of the construction product: System 1

6. Harmonized standard: EN 14604:2005/AC:2008

#### Notified body/ bodies:

TUV Rheinland InterCert Kft.,

Performed type testing and the initial inspection of the manufacturing plant and of the factory production control with continuous surveillance assessment and approval of the factory production control under system ISO9001:2015 and issued following certificate of conformity No. 1008-CPR-MC 69265714

#### 7. Declared performance:

All requirements including all Essential Characteristics and the corresponding performances for the intended use of uses have been determined as described in the EN mentioned in the table below

Main Features	Performance	Harmonized technical specification
Nominal activation conditions / sensitivity /	Pass	Art 4.12, 5.2 to 5.6, 5.15, 5.17, 5.18, 5.20

<u>Heiman</u> 语号

# 深圳市海曼科技股份有限公司

Shenzhen Heiman Technology Co., Ltd.

response delay / response delay (response		
time) and performances under fire conditions		
Operating Reliability	Pass	Art 4.1, 4.2, 4.3, 4.5, 4.6, 4.7, 4.9, 4.10, 4.13
		to 4.17, 4.19, 5.11, 5.16, 5.22, 5.24
Tolerance on supply voltage	Pass	Art 5.21
Durability of operational reliability and	Pass	Art 5.7 and 5.8
response delay, Temperature resistance		
Durability of operational reliability, Vibration	Pass	Art 5.12 and 5.13
resistance		
Durability of operational reliability, Vibration	Pass	Art 5.9
resistance		
Durability of operational reliability,	Pass	Art 5.10
Corrosion resistance		
Durability of operational reliability, Electrical	Pass	Art 5.14
stability		
Alarms suitable for installation in leisure	N/A	ANNEX L
accommodation vehicles		

#### 8. Appropriate technical documentation and / or special technical documentation:

The performance of the above products conform to the specified performance. This declaration of performance has been issued in accordance with Regulation (EU) No 305/2011 in the sole responsibility by the manufacturer listed above.

